



NOTE

- 2.1

REFUSE FEEDING TABLE

SC-90

B-2

H.T.B

S.I.B

145mm

65mm

25t

50t

285mm
- 2.2

REFUSE FEED AREA

SC-90

B-2

KOSALITE-20VS

327.5mm

125mm

105mm

557.5mm
- 2.3

SIDE WALL

SC-90

B-5

B-2

KOSALITE-20VS

150mm

125mm

125mm

100mm

500mm
- 2.4

SIDE WALL OF FURNACE

CRT-SC70

72mm
- 2.5

SIDE WALL OF FURNACE

CRT-SC30

72mm
- 2.6

ROOF OF FURNACE

CRESTO-75

102mm
- 2.7

FRONT, REAR AND WALLS

CRT-SC70

72mm
- 2.8

REAR WALL

HX-34HD

B-5

B-2

KOSALITE-20VS

150mm

65mm

230mm

125mm

570mm
- 2.9

ASH FALL CHUTE

HX-34HD

H.T.B

S.I.B

115mm

25t

50t

190mm
- 2.10

ASH HOPPER

KOSACAST-SP

S.I.B

140mm

50t

190mm
- 2.11

BURNER WALL BOX

CRESTO-75

200mm
- 2.12

INSPECTION HOLE

KOSACAST-SP
- 2.13

ACCESS DOORS

KOSALITE-20VS
- 2.14

LOWER HEADER FRONT WALL

CRESTO-75

72mm
- 2.15

LOWER HEADER REAR WALL

CRESTO-75

72mm
- 2.16

HEADER DIVISION WALL

CRT-SC70

72mm
- 2.17

HEADER BOILER ROOF

CRT-SC70

72mm

NO.	PARTSNAME	MATERIAL	STANDARD	Q'TY/SET	MAT LW	REMARKS
△						
△						
△						
REV.	DATE	DESCRIPTION OF REVISION			REV'D	CH'D APP'D
DWG	G.H.JUNG	△ HYUNDAI ENGINEERING AND CONSTRUCTION CO.,LTD. POOSUNG 韓國耐火株式會社 군포 쓰레기 소각시설 건설공사				
CHK						
APP						
DATE	99.08.03					
UNIT	MM INCH	PROJECT	NAME			
SCALE	1:60	DWG. NO.	HD - FS - IN -001			
ITEM NO.		REV.	SHT. NO.			
		△	1/1			

NO.	PARTSNAME	MATERIAL	STANDARD	Q'TY/SET	MAT LW	REMARKS
						
						
		FIRST ISSUE			G.H JUNG	N.S PARK
REV.	DATE	DESCRIPTION OF REVISION		REV'D	CHE'D	APP'D
DWG	G.H.JUNG	 HYUNDAI ENGINEERING AND CONSTRUCTION CO.,LTD.				
CHK						
APP		 韓國耐火株式會社				
DATE	99.08.06					
	PROJECT	군포 쓰레기 소각시설 건설공사				
UNIT	MM	INCH				
SCALE	1:25					
ITEM NO.	DWG. NO.	HD - FS - BL - 005			REV.	SHT. NO.
						1 / 1